

VALVE DETAILS

- > Series 3W/3L Resilient Seated Butterfly Valve
- > Wafer | Lug
- > NPS 2 to 24 | DN 50 to 600
- > Bray Series 3W Wafer or Series 3L Lug or approved equal.

BODY

- > Shall be one-piece wafer or lug design with extended neck to allow for 2" of piping insulation.
- > Flange locating holes shall be provided on wafer bodies to allow for quick and precise alignment during valve installation.
- > Flange hole drilling per international flange standard as specified.
- > A non-corrosive bushing and a self-adjusting stem seal shall be provided. No field adjustment shall be necessary to maintain optimum field performance.

DISC

- > Disc edge and hub on metal discs shall be precision machined and polished to minimize torque and maximize sealing capability.

STEM

- > Shall be one-piece design to maximize disc support and strength.
- > Disc to stem connection shall be an internal double "D" design with no possible leak paths in the disc-to-stem connection. External disc-to stem connections such as disc screws or pins are not allowed.
- > Stem shall be mechanically retained in the body neck and no part of the stem shall be exposed to the line media.

SEAT

- > The rubber seat shall be directly molded into the valve body for optimum performance and a long cycle life.
- > The seat shall totally encapsulate the body isolating it from the line media.
- > No flange gaskets shall be required.
- > Seat flange face design shall be tear drop shaped to provide maximum sealing surface to mate with many flange types and materials.
- > Lug style design must allow for sealing at full rated pressure with the downstream flange removed.
- > During valve installation and flange tightening, seat design must allow disc to be in the closed position without any performance concerns.

BEARINGS, BUSHINGS, AND STEM SEALS

- > Provided with top and bottom stem bearings consisting of a 316 stainless steel shell with a TFE/glass fabric liner bearing surface.
- > A non-corrosive bushing and a self-adjusting stem seal shall be provided.
- > No field adjustment shall be necessary to maintain optimum field performance.



APPROVALS AND CERTIFICATIONS

- > CE/PED
- > ANSI/NSF 61/372
- > EC1935
- > FDA Food Contact Approved
- > ABS Type Approved
- > Bureau Veritas Type Approved

VALVE ACTUATOR MOUNTING PAD

- > ISO 5211

TESTING

- > Manufactured, assembled, and tested in compliance with a written ISO 9001 quality assurance program.
- > Valve shall be shell tested to 1.5x rated pressure.
- > Valve shall be leak tightness tested to 1.1x rated pressure.

PRESSURE RATINGS

- > Valve shall be rated for bubble-tight shut-off at pressure ratings shown below.

BI-DIRECTIONAL

- > High Pressure Disc
 - NPS 2 to 24 | DN 50 to 600
 - 250 psi (17.2 bar)

- > Standard Disc
 - NPS 2 to 12 | DN 50 to 300
 - 175 psi (12 bar)

 - NPS 14 to 24 | DN 350 to 600
 - 150 psi (10.3 bar)

- > Low Pressure Disc
 - NPS 2 to 24 | DN 50 to 600
 - 50 psi (3.4 bar)

DEAD-END SERVICE (LUG BODY ONLY WITH DOWNSTREAM FLANGE REMOVED)

- > High Pressure Disc
 - NPS 2 to 24 | DN 50 to 600
 - 250 psi (17.2 bar)

- > Standard Disc
 - NPS 2 to 12 | DN 50 to 300
 - 175 psi (12 bar)

 - NPS 14 to 24 | DN 350 to 600
 - 150 psi (10.3 bar)

- > Low Pressure Disc
 - NPS 2 to 24 | DN 50 to 600
 - 50 psi (3.4 bar)