# **7 Bray** CONTROLS

### BRAY RECOMMENDED SPECIFICATIONS

## Series 36H Resilient Seated Valve

#### Valve Type:

#### Bray Series 36H Double Flanged or approved equal. Body:

- Shall be one-piece double flanged design.
- Flange hole drilling per international flange standard as specified.
- Provided with upper and lower bronze stem bearings to absorb actuator side thrust and minimize friction torque.
- Equipped with an externally adjustable stem packing system that allows packing adjustment without removing the actuator.

#### Disc:

• Disc edge and hub on metal discs shall be spherically machined and hand polished for minimum torque and maximum sealing capability.

#### Stem:

- Shall be one-piece design
- Stem shall be provided with blow-out proof stem retention system to assure full retention of the stem in the unlikely event of an internal stem failure.

#### Seat:

- Shall be tongue-and-groove bonded seat with a primary hub seal and a molded flange O-ring suitable for weld-neck and slip-on flanges.
- The seat shall totally encapsulate the body isolating it from the line media and no flange gaskets shall be required.

#### Testing:

• Valve shall be tested to 110% of the rated pressure.

#### Approvals & Certifications:

- CE/PED Certification
- NSF/ANSI 61-2008 Certification (Potable Water)
- SIL Certification



#### Pressure Ratings:

Valve shall be rated for bubble-tight shut-off at pressure rating shown below.

#### **Bi-directional Service**

(With downstream flanges and disc in closed position):

#### All Resilient Seated Series 36H Valves:

• 22"-60" (550mm-1500mm) 232 psi (16.0 Bar)

#### **Dead-End Service**

(No downstream flanges and disc in closed position):

#### All Series 36H Valves:

• 22"-60" (550mm-1500mm) 150 psi (10.3Bar)